




CDVI

31, av. du Gal Leclerc
93500 PANTIN FRANCE
Tel : 33 (0)1 48 91 01 02
Fax : 33 (0)1 48 91 21 21
www.cdvi.com

ARD24

POWER SUPPLY FILTERED
REGULATED AND STABILIZED

I
N
S
T
R
U
C
T
I
O
N
M
A
N
U
A
L



FUSES

F1: Primary fuse 0.315 Amp

F2: Secondary fuse 1.6 Amp

Terminal	Voltage
-	0V= -
+	24V= +

This power supply was design to support a load of 1 Amp @ 12VDC Max.